

NOTES:

1. MINOR FASTENERS, SOME PIPE SUPPORTS AND INSULATION NOT SHOWN FOR CLARITY.
2. STRUCTURAL STEEL GALVANISED TO AS4680.
3. PIPING PRESSIT COPPER WITH 25mm EPDM FOIL BACKED INSULATION.
4. SKID TO BE INSTALLED ON A LEVEL SLAB. FOR ANY VARIATION IN FLOOR LEVEL SHIMS SHALL BE USED TO SUIT SKID NATURAL SHAPE.
5. RECOMMENDED 1.2m CLEARANCE ON ALL SIDES FOR SERVICE ACCESS
6. WHEN LIFTING WITH LIFT LUGS A SPREADER BAR WITH MINIMUM 2.4m WIDTH MUST BE USED TO AVOID DAMAGING THE EQUIPMENT.
7. APPROXIMATE DRY WEIGHT: 2,820 kg
APPROXIMATE WET WEIGHT: 7,640 kg

ITEM	PART No	DESCRIPTION	QTY
6		STRUCTURAL SKID FRAME	1
5		ELECTRICAL CONTROL PANEL	1
4		EXPANSION TANK AND ACCESORIES	1
3		STIEBEL ELTRON WATER PUMP	5
2		STIEBEL ELTRON OUTDOOR TANK	5
1		STIEBEL ELTRON WPL-A 07 HEAT PUMP	5


GENERAL ARRANGEMENT DOMESTIC HOT WATER SYSTEM CM-T 55 SKID CONFIGURATION ARTICLE ID: 207796			
DWG No:	B1186-DWG-GAD-M-0005	SHEET:	1/1
REV:	A		

UNLESS OTHERWISE SPECIFIED
DIMENSIONS ARE IN MILLIMETERS
THIRD ANGLE PROJECTION
FABRICATION TOLERANCE: ± 2.0mm
MACHINED TOLERANCE: ± 0.5mm

THIS DRAWING IS CONFIDENTIAL AND
THE PROPERTY OF RUBIGO GROUP PTY
LTD. REPRODUCTION OR DISTRIBUTION
RIGHTS ARE RESERVED EXCLUSIVELY TO
RUBIGO GROUP PTY LTD UNLESS
OTHERWISE AGREED

STIEBEL ELTRON

DO NOT SCALE
DRAWING



REV	DATE	DESCRIPTION	DRN	CHK	APP
A	13/05/2025	FIRST RELEASE	JM	TS	BR

SIZE: A3 SCALE: N.T.S
TEMPLATE: B0099-DWG-ADM-G-0001